

**ST. JOHNS COUNTY UTILITY DEPARTMENT
2F - INSPECTION - PRESSURE AND LEAKAGE TEST REPORT
HDPE ONLY PER ASTM F2164**

Project: _____ Date: _____

Location of Pressure Test: _____ By: _____

Main Type (Check One): Water Sewer Reuse

The subject pressure test was held today at _____ and _____.

In addition to me, the following were present:

1. _____ 3. _____

2. _____ 4. _____

Time of Test: Begin: _____ End: _____

Pressure (PSI): Begin: _____ End: _____

ROAD NAME	STATION BEGIN/END	PIPE SIZE (in)	LENGTH (ft)	ALLOWABLE LEAKAGE (gal)	PASS/ FAIL

Watermain and Reclaimed Watermain: 150 PSI or Pipe Rating

Forcemain: 100 PSI or Pipe Rating

NOTE: WHEN TESTING AGAINST EXISTING CLOSED METAL SEATED VALVES, AN ADDITIONAL LEAKAGE PER CLOSED VALVE OF 0.0078 GAL/hr/in. OF NOMINAL VALVE SIZE SHALL BE ALLOWED.

Email this completed form to Construction Technician ConstructTech@sjcfl.us. Call 904-209-2618 with questions.