

GENERAL FLAMMABLE AND COMBUSTIBLE LIQUIDS STORAGE CHECKLIST

All code references are to NFPA 30, 1996 edition, unless otherwise noted.

- 1) Pass _____ Fail _____ N/A _____
Storage of liquids shall not physically obstruct means of egress (4-4.3.1)
- 2) Pass _____ Fail _____ N/A _____
Rack storage must have a minimum of 4 ft. wide aisles between rack sections and between racks and adjacent liquid storage. (4-4.3.3)
- 3) Pass _____ Fail _____ N/A _____
Main aisles in rack storage are a minimum of 8 ft. wide. (4-4.3.3)
- 4) Pass _____ Fail _____ N/A _____
In unprotected areas, pallets are stored in a maximum pile size of 2,500 square feet and a maximum storage height of 6 ft. and pallets are separated from liquid storage at least 8 feet wide. (4-4.3.7)
- 5) Pass _____ Fail _____ N/A _____
Containers are stacked to provide stability and prevent excess stress on container walls. (4-4.3.8)