

ST. JOHNS COUNTY, FLORIDA

Board of County Commissioners

FIRE RESCUE

3657 GAINES ROAD
SAINT AUGUSTINE, FLORIDA
32084-6565



PHONE: (904) 209-1700
FAX: (904) 209-1726

Requirements for Selling Fireworks and Sparklers at Approved Sites

- *Only sites approved by the lottery can sell 1.4 G Fireworks
- *Sales of fireworks shall be within 150 feet of a public way and Fire Department access
- *Tents/canopies/stands shall be at least 20 feet away from buildings, storage containers, and other tents
- *Conex storage containers are to be used for storage only and shall be at least 20 feet from tents/canopies
- *Firework sales shall be at least 50 feet from fueling dispensers, fuel vent pipes, and propane dispensers
- *No open flame within 50 feet of the fireworks sales
- *Post signs with letters of minimum 2 inches "FIREWORKS: NO SMOKING" and "NO FIREWORKS DISCHARGED WITHIN 300 FEET"
- *Firework sales area shall be at least 30 feet away from dry grass and brush
- *All parking shall be at least 10 feet away from firework sales except for deliveries
- *Minimum of 2 fire extinguishers with a minimum 4A rating, at least one shall be pressurized water
- *If sales are after dusk, emergency lights and exit signs continuously illuminated are required

I have read the requirements above and will abide by them including those in the Florida Fire Prevention Code as adopted by the State of Florida.

Signature

Print name