

# Fire Marshal Permit

## RETAIL SALES OF STATE APPROVED SPARKLERS/ FIREWORKS IN TENTS, OPEN AREAS, Etc.

3657 Gaines Rd - St. Augustine, FL 32084  
Phone: 904-209-1740 Fax 904-209-1754

Company _____			
Mailing Address _____			
Parcel #	<input style="width: 150px; height: 20px;" type="text"/>	Building Permit #	<input style="width: 150px; height: 20px;" type="text"/>
Contact	_____	Phone	_____
		Cell	_____
		Fax	_____
Dates of Sale	_____	Sales Location	_____
Retail Sales Permit Expires	_____	Fireworks Storage Address	_____

**RETAIL SPARKLER/FIREWORKS Permit Fee \$54.00 & TENT Permit Fee \$54.00 = \$108.00**

**Copies of the following documents must be attached to this Permit Application or shown on the plans. SUBMIT 2 SETS**

1. List of all approved products to be sold, max gross weight and quantity.
2. Copy of certificate issued from the State Fire Marshal allowing the sales of sparklers. *Must be kept on site.*
3. Identify total max gross weight of sparklers and pyrotechnic composition that will be on site at any one time.
4. The maximum allowable stand size is 800 square feet. NFPA 1.65.11.4.1
5. Tent must be flame resistant. Copy of certification is required and *must also be kept on site.*
6. Provide a site plan containing the information found on the attached "Fireworks and Sparklers Sales in Tents Checklist".
7. Consumer fireworks devices that are damaged shall be removed and not offered for sale.
8. Minimum of two (2) fire extinguishers with a minimum 2A rating, at least one of which shall be pressured water. Max travel distance to an extinguisher shall not exceed 35 feet. (7.5.2). Temporary consumer fireworks retail sales stand of less than 200 square feet requires only one (1) extinguisher.
9. Each side of tent shall have signs with letters at minimum two (2) inches in height, stating "FIREWORKS: NO SMOKING" and "NO FIREWORKS DISCHARGE WITHIN 300 FEET".

**Important to Note:**

- A) Prior to issuing this permit, the Fire Marshal's office will review all submitted materials and will conduct a site visit. If any negative issues are found, the permit process may be delayed. At that point we will contact you and advise you of those issues. Once a permit has been issued, a fire inspector shall conduct an inspection of premises.
- B) Per NFPA Life Safety Code 101, Section 11.11(Tents) shall comply with Section 36 (Mercantile) which does not allow high hazards, i.e. FIREWORKS to be sold in tents. F.S.S. 791 Sale of Fireworks only permits State Approved Sparklers and fireworks to be sold in tents and stands.

<b>OFFICIAL USE ONLY</b>					
<b>TENT</b>	APPROVED _____	REJECTED _____	<b>SPARKLERS</b>	APPROVED _____	REJECTED _____
OT # _____	PERMIT # _____		FHID _____		
_____ Signature of Fire Department Representative / Date					(Revised 10/09)